

## **CERTIFICATE OF CONFORMITY**

No. CLS1B 13 07 81381 002

Certificate Holder: Samcom Electronics Pte Ltd

Shun Li Industrial Park 89 Kaki Bukit Avenue 1 Singapore 417957 SINGAPORE

**Certification Mark:** 



Product: Emergency Exit Signs

Brand Name: SAMCOM

Model(s): SLM18-001, SLM18-011, SLM18-012 and SLM18-021

Product Rated: 230V~ 50/60Hz

Details: Load : 1 x 8W Fluorescent Lamp

Battery: 2.4V 2.5AH Ni-Cd

\*Former CoC 022827\*

**Standard(s):** SS 263-2:1998

SS CP 19/A2:2005

Country of Origin Singapore

Test Report(s): 719176076-EEC10-LJH

**Issued on:** 2013-07-05

**Valid until:** 2014-07-06

Products listed under Class 1B must have TÜV SÜD PSB PLS mark as shown above affixed/printed on them. Failure to comply with this requirement may result in revocation of this certificate.

Vice-President (Certification Department)
TÜV SÜD PSB

Page 1 of 1

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at www.tuv-sud-psb.sg



