



PSB Singapore

# CERTIFICATE OF CONFORMITY

No. CLS1B 15 02 81381 018

**Certificate Holder:** Samcom Electronics Pte Ltd  
89 Kaki Bukit Avenue 1  
Shun Li Industrial Park  
Singapore 417957  
SINGAPORE

**Certification Mark:**



TÜV SÜD PSB

**Product:** Emergency Exit Signs

**Brand Name:** SAMCOM

**Model(s):** ELW18

**Product Details:**  
Rated : 230V 50/60Hz  
Load : 1 x 8W T5 FLUORESCENT  
Battery : 2.4V 2.5AH Ni-Cd  
Duration : 1.5 Hrs  
IP Rating: IP 65

**Standard(s):**  
SS 263-2/A2:2008  
SS 563-1:2010( cl 10 & 11)  
SS 563-2/A1:2013(cl 5.2,5.4,5.5,6,8,9,10.6 & 10.7)

**Country of Origin:** Singapore

**Test Report(s):** 7191097747-EEC14/01-HPW,  
7191097747-EEC14/02-HPW

**Issued on:** 2015-02-04

**Valid until:** 2018-02-03

Products listed under Class 1B must have TÜV SÜD PSB PLS mark as shown above affixed/printed on them. Failure to comply with this requirement may result in revocation of this certificate.

Page 1 of 1

Vice-President (Certification Department)  
TÜV SÜD PSB

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at [www.tuv-sud-psb.sg](http://www.tuv-sud-psb.sg)