



PSB Singapore

CERTIFICATE OF CONFORMITY

No. CLS1B 16 04 81381 021

Certificate Holder: Samcom Electronics Pte Ltd
89 Kaki Bukit Avenue 1
Shun Li Industrial Park
Singapore 417957
SINGAPORE

Certification Mark:



TÜV SÜD PSB

Product: Emergency Exit Signs

Brand Name: SAMCOM

Model(s): (1) SLM18-001 (2) SLM18-011 (3) SLM18-021

Product Details:
Rated : 230VAC 50/60Hz 8W
Load : 1 x 8W Fluorescent Lamp
Battery : 2.4V 2.5Ah Ni-Cd
Duration : 1hr 30min

Standard(s):
SS 263-2/A1:2008
SS 563-1:2010 (cl 10 & 11)
SS 563-2/A1:2013 (cl 5, 5.2, 5.4, 5.5, 6, 8, 9, 10.6 & 10.7)

Country of Origin: Singapore


Test Report(s): 7191130341-EEC16-KYM

Issued on: 2016-04-29

Valid until: 2019-04-28

Products listed under Class 1B must have TÜV SÜD PSB PLS mark as shown above affixed/printed on them. Failure to comply with this requirement may result in revocation of this certificate.

Page 1 of 1


Vice-President (Certification Department)
TÜV SÜD PSB

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at www.tuv-sud-psb.sg

